

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-15-03-09-01

- Product:** Laminate floor covering "Kronotex"
with the structures: PR, MO, WG, BS, CP, HG
- Client:** Swiss Krono Group
KRONOTEX GmbH & Co. KG
Wittstocker Chaussee 1
16909 Heiligengrabe
- Order:** Determination of the slip resistance according to EN 13893:2003 /
classification according to EN 14041:2008
- Test report:** 2715138
- Results:**


Structure	Property	Result	Declaration according to EN 14041:2008
PR	Slip resistance according to EN 13893:2003	$\mu = 0.39$	class DS
MO		$\mu = 0.62$	class DS
WG		$\mu = 0.61$	class DS
BS		$\mu = 0.44$	class DS
CP		$\mu = 0.54$	class DS
HG		$\mu = 0.96$	class DS

The tested laminate floor coverings "Kronotex" with the structures PR, MO, WG, BS, CP and HG are fulfilling the requirement of the class DS ($\mu \geq 0.3$) according to EN 14041:2008.

Dresden, 09 March 2015



Head of laboratory

Engineer in charge